

Sponsor: Lee Pan VR Medical Technology Co. 90 Gao Xin Rd., Zhouzhuang Kunshan, Jiangsu CN 215325

Bacterial Filtration Efficiency (BFE) at an Increased Challenge Level Final Report

Test Article: VR 010 Lot # SY1502007

Laboratory Number:

809059

Study Received Date:

11 Mar 2015

Test Procedure(s): Standard Test Protocol (STP) Number: STP0009 Rev 07

Summary: This procedure was performed to evaluate the BFE at an increased challenge level of the test article. A suspension of Staphylococcus aureus, ATCC #6538, was delivered to the test article to determine filtration efficiency. A challenge level of greater than 10⁷ colony forming units (CFU) was pumped through a nebulizer using a peristaltic pump at a controlled flow rate and fixed air pressure. The aerosol droplets were generated in a glass aerosol chamber and drawn through the test article into all glass impingers (AGIs) in parallel. The challenge was delivered for a one minute interval and sampling through the AGIs was conducted for two minutes to clear the aerosol chamber.

This test procedure was modified from Nelson Laboratories, Inc. (NLI), standard BFE procedure in order to employ a more severe challenge than would be experienced in normal use. This method was adapted from ASTM F2101. All test method acceptance criteria were met. Testing was performed in compliance with US FDA good manufacturing practice (GMP) regulations 21 CFR Parts 210, 211 and 820.

Challenge Flow Rate:

30 Liters per Minute (L/min)

Area Tested: Entire Test Article

Side Tested: ~22 mm OD Port

Results:

Test Article Number	Total CFU Recovered	Filtration Efficiency (%)
	1.0×10^2	99.99934
2.02.22.23.23.23.23.23.23.23.23.23.23.23.23	5.6 x 10 ¹	99.99963
3	4.5 x 10 ¹	99.99970

Challenge Level: 1.5 x 10⁷ CFU

Mean Particle Size (MPS): ~3.2 µm

The filtration efficiency percentages were calculated using the following equation:

 $\% BFE = \frac{C-T}{C} \times 100$

C = Challenge Level T = Total CFU recovered downstream of the test article

P.O. Box 571830 | Murray, UT 84157-1830 U.S.A. 6280 South Redwood Road | Salt Lake City, UT 84123-6600 U.S.A. www.nelsonlabs.com · Telephone 801 290 7500 · Fax 801 290 7998 · sales@nelsonlabs.com

FRT0009-0001 Rev 6 Page 1 of 1

These results relate only to the test article listed in this report. Reports may not be reproduced except in their entirety. Subject to NLI terms and conditions at www.nelsonlabs.com



Sponsor: Lee Pan VR Medical Technology Co. 90 Gao Xin Rd., Zhouzhuang Kunshan, Jiangsu CN 215325

Viral Filtration Efficiency (VFE) at an Increased Challenge Level Final Report

Test Article: VR 010 Lot # SY1502007

Laboratory Number: Study Received Date:

809058 11 Mar 2015

Test Procedure(s): Standard Test Protocol (STP) Number: STP0010 Rev 07

Summary: This procedure was performed to evaluate the VFE at an increased challenge level of the test article. A suspension of ΦX174 bacteriophage was delivered to the test article to determine filtration efficiency. A challenge level of greater than 10⁶ plaque-forming units (PFU) was pumped through a nebulizer using a peristaltic pump at a controlled flow rate and a fixed air pressure. The aerosol droplets were generated in a glass aerosol chamber and drawn through the test article into all glass impingers (AGIs) in parallel. The challenge was delivered for a one minute interval and sampling through the AGIs was conducted for two minutes to clear the aerosol chamber.

This test procedure was modified from Nelson Laboratories, Inc. (NLI), standard VFE test in order to employ a more severe challenge than would be experienced in normal use. All test method acceptance criteria were met. Testing was performed in compliance with US FDA good manufacturing practice (GMP) regulations 21 CFR Parts 210, 211 and 820.

Challenge Flow Rate: 30 Liters per minute (L/min)

Area Tested: Entire Test Article

Side Tested: ~22 mm OD Port

Results:

Tool Article Niverbour	Total DELL Deserved	Filtration Efficiency (0/)
Test Article Number	harman and the commence of the	Filtration Efficiency (%)
	1.4×10^2	99.9977
2	2.4×10^2	99.9962
3	1.8×10^2	99.9972

Challenge Level: 6.3 x 10⁶ PFU

Mean Particle Size (MPS): ~3.2 μm

The filtration efficiency percentages were calculated using the following equation:

 $\% VFE = \frac{C - T}{C} \times 100$

C = Challenge Level

T = Total PFU recovered downstream of the test article

Janelle R. Bentz, M.S.

571830 | Murray, UT 84157-1830 U.S.A. · 6280 South Redwood Road | Salt Lake City, UT 84123-6600 U.S.A www.nelsonlabs.com · Telephone 801 290 7500 · Fax 801 290 7998 · sales@nelsonlabs.com

FRT0010-0001 Rev 6

Page 1 of 1